



TABLA DE PRESIÓN - TEMPERATURA

F°	C°	R-12	R-22	R-502	R-134 A	R-507	R-401 A	R-404 A
-50	-45.6	15.4	6.2	0.2	18.4	0.9	18.5	0.0
-48	-44.4	14.6	4.8	0.7	17.7	1.7	17.7	0.8
-46	-43.3	13.8	3.4	1.5	17.0	2.6	17.0	1.6
-44	-42.2	12.9	2.0	2.3	16.2	3.5	16.0	2.5
-42	-41.1	11.9	0.5	3.2	15.4	4.5	15.0	3.4
-40	-40.0	11.0	0.5	4.1	14.5	5.5	14.5	5.5
-38	-38.9	10.0	1.3	5.0	13.7	6.5	13.5	6.5
-36	-37.8	8.9	2.2	6.0	12.8	7.6	12.5	7.5
-34	-36.7	7.8	3.0	7.0	11.8	8.7	11.5	8.6
-32	-35.6	6.7	4.0	8.1	10.8	9.9	10.6	9.7
-30	-34.4	5.5	4.9	9.2	9.7	11.1	9.0	10.8
-28	-33.3	4.3	5.9	10.3	8.6	12.4	8.3	12.0
-26	-32.2	3.0	6.9	11.5	7.7	13.7	7.0	13.2
-24	-31.1	1.6	7.9	12.7	6.2	15.0	6.0	14.5
-22	-30.0	0.3	9.0	14.0	4.9	16.4	4.5	15.8
-20	-28.9	0.6	10.1	15.3	3.6	17.8	3.5	17.1
-18	-27.8	1.3	11.3	16.7	2.3	19.3	2.0	18.5
-16	-26.7	2.1	12.5	18.1	0.8	20.9	0.5	20.0
-14	-25.6	2.8	13.8	19.5	0.3	22.5	0.4	21.5
-12	-24.4	3.7	15.1	21.0	1.1	24.1	1.4	23.0
-10	-23.3	4.5	16.5	22.8	1.9	25.8	2.2	24.6
-8	-22.2	5.4	17.9	24.2	2.9	27.6	3.1	26.3
-6	-21.1	6.3	19.3	25.8	3.6	29.4	3.9	28.0
-4	-20.0	7.2	20.8	27.5	4.5	31.3	4.8	29.8
-2	-18.9	8.2	22.4	29.3	5.5	33.2	5.7	31.6
0	-17.8	9.2	24.0	31.1	6.5	35.2	6.7	33.5
2	-16.7	10.2	25.6	32.9	7.5	37.3	8.0	34.8
4	-15.6	11.2	27.3	34.9	8.5	39.4	8.8	37.4
6	-14.4	12.3	29.1	36.9	9.6	41.6	9.9	39.4
8	-13.3	13.5	30.9	38.9	10.8	43.8	11.0	41.6
10	-12.2	14.6	32.8	41.0	12.0	46.2	12.2	43.7
12	-11.1	15.8	34.7	43.2	13.1	48.5	13.4	46.0
14	-10.0	17.1	36.7	45.4	14.4	51.0	14.6	48.3
16	-8.9	18.4	38.7	47.7	15.7	53.5	15.9	50.7
18	-7.8	19.7	40.9	50.0	17.0	56.0	17.2	53.1
20	-6.7	21.0	43.0	52.5	18.4	58.8	18.6	55.6
22	-5.6	22.4	45.3	54.9	19.9	61.5	20.0	58.2
24	-4.4	23.9	47.6	57.5	21.4	64.3	21.5	60.9
26	-3.3	25.4	49.9	60.1	22.9	67.2	23.0	63.6
28	-2.2	26.9	52.4	62.8	24.5	70.2	24.8	66.5
30	-1.1	28.5	54.9	65.6	26.1	73.3	26.2	69.4
32	0.0	30.1	57.5	68.4	27.8	76.4	27.9	72.3
34	1.1	31.7	60.1	71.3	29.5	79.6	29.9	75.4
36	2.2	33.4	62.8	74.3	31.3	82.9	31.3	78.5
38	3.3	35.2	65.6	77.4	33.2	86.3	33.2	81.8
40	4.4	36.9	68.5	80.5	35.1	89.8	35.0	85.1
42	5.6	38.8	71.5	83.8	37.0	93.4	37.0	88.5
44	6.7	40.7	74.5	87.0	39.1	97.0	39.0	91.9
46	7.8	42.7	77.6	90.4	41.1	100.8	41.0	95.5
48	8.9	44.7	80.7	93.9	43.3	104.6	43.1	99.2
50	10.0	46.7	84.0	97.4	45.5	108.6	45.3	102.9
52	11.1	48.8	87.3	101.0	47.7	112.6	60.0	109.0
54	12.2	51.0	90.8	104.8	50.1	116.7	62.0	113.0
56	13.3	53.2	94.3	108.6	52.3	121.0	65.0	117.0
58	14.4	55.4	97.9	112.4	55.0	125.3	68.0	121.0
60	15.6	57.7	101.6	116.4	57.5	129.7	70.0	125.0
62	16.7	60.1	105.4	120.4	60.1	134.3	73.0	130.0
64	17.8	62.5	109.3	124.6	62.7	139.0	76.0	134.0
66	18.9	65.0	113.2	128.8	65.5	143.7	79.0	139.0
68	20.0	67.6	117.3	133.2	68.3	148.6	82.0	140.0

Referencias

Rojo = Vacío
 Negro = Vacío (psig)
 Azul = Líquido (psig)

FAI-CAF S.R.L.

29 de Septiembre 3834 - B1826GLB - Remedios de Escalada
 Buenos Aires - República Argentina
 Tel./Fax.: (54-011) - 4242-3749 / 4242-7755 / 4288-0399